

LAND USE

100 Attachment 2

Township of Holland

**Appendix B
Water Demand for Residential Development
[Amended 12-30-1981 by Ord. No. 81-23]**

For residential development, water demand shall be calculated as follows:

Dwelling Type	Gallons per day
Studio or 1-bedroom apartments	190
2- or more bedroom apartments	280
Townhouses	
Up to 2 bedrooms	280
Over 2 bedrooms	350
Single-family dwellings	350

Where information is available as to actual water usage in an existing water supply system, in lieu of the above, the average daily water usage over the prior one-year period by already existing development may be used.