

AN ORDINANCE AMENDING
TITLE 17, ZONING, REGARDING SET-BACKS FOR TANKS
PROVIDING STORAGE OF FLAMMABLE LIQUIDS

WHEREAS, the City of Byron has the authority to regulate matters affecting the health, safety and welfare of the community; and

WHEREAS, the current City Ordinance regulating set-backs for tanks providing storage of flammable liquids is inconsistent with the State Fire Code; and

WHEREAS, the State Fire Code provides a sufficient set-back requirement for tanks providing storage for flammable liquids.

NOW, THEREFORE, BE IT ORDAINED by the Mayor and the City Council of the City of Byron, Ogle County, Illinois, as follows:

SECTION 1: Section 17.38.090F1 (formally 17.40.202F1), shall be amended to read in its entirety as follows:


17.38.090F. Fire and Safety Hazards.

1. All tanks providing storage of flammable liquids above ground shall be located 25 feet from property lines and 25 feet from the nearest occupied structure. All tanks providing storage of flammable liquids below ground shall be located not closer to the property line than the greatest depth to the bottom of the buried tank.

SECTION 2: Any ordinances or resolutions, or parts thereof, inconsistent with this ordinance are be repealed.

SECTION 3: This ordinance shall become effective upon its passage as provided by law.

PASSED and APPROVED by the City Council of the City of Byron this 5th day of January, 2011.



Mayor, Christopher Millard

ATTEST:



City Clerk, Kim Gouker

AYES: Huber, Rickard, Isaacs, Hillis, Coyne
 NAYS: _____
 ABSENT: Hanlin, Palmgren
 ABSTENTIONS: _____