

ZONING CODE

156 Attachment 25

Village of Coal City

**Table 23: Standards for Flammable Liquids and Gases**

Open Cup Flash Point in Degrees Fahrenheit	Maximum Gallons Above Ground		Maximum Gallons Below Ground	
	Heavy Industrial	Other	Heavy Industrial	Other
Under 100	62,000	3,000	No maximum	100,000
100 to 139	100,000	10,000	No maximum	100,000
140 and over	200,000	20,000	No maximum	100,000

**NOTES:**

Storage of finished products in original sealed containers of 55 gallons or less is exempt from above standards.

Maximum cubic feet of flammable gases at standard temperature and pressure shall be 30 times the gallonage figures above.